



ADDENDUM NUMBER I
CSP for Brooks City Base - Tejada Complex Area,
Demolition of Buildings & Foundations
Revised Bid Form and Clarifications
Bid #05102016-014

To: All Attending Bidders

From: Lucynda Massey, Procurement Manager

Date: May 24, 2016



1. The Revised Bid Form is posted to the BDA website (<http://www.brookscity-base.com/development/vendors-bids/>).
2. Contractor is responsible for all costs associated with permitting and implementation of the SWPPP plan.
3. There is approximately 180cy of concrete without re-bar along the west drive of the Tejada complex that has been dumped from other construction site that is to be included in the concrete crushing price.
4. The ONLY sidewalks to be demolished are those connecting the buildings to the driveways / streets.
5. The concrete blocks in the buildings CANNOT be crushed with the concrete and mixed with the material we intend to use as road base. Plan to haul off the block.